

## Electrical Safety

SafetyNet #512

Revised: 7/10/2020

### A. Summary

Improper use of extension cords and surge protectors can present a serious fire safety hazard in the workplace. The most common cause of fires from extension cords is improper use and/or overloading, especially when the cord has multiple outlets.

The 2016 California Fire Code Chapter 6 Section 605 addresses the use of extension cords, power taps, surge suppressors, and multi plug adaptors. Follow the guidelines below to reduce the risk of fire due to overloaded or improperly used extension cords or surge protectors.

### B. Extension Cords

Approved Extension Cords Must:

1. Be Underwriter Laboratories (UL) listed.
2. Be at least 12-14 gauge wire and not be less than the rated capacity of the appliance.
3. Have a ground wire and not be bypassed or rendered inoperable.
4. Be used only for temporary situations, such as laboratory experiments lasting no longer than 90 days, and not used in place of permanent wiring.
5. Connect to only one portable (easily moved from one place to another during use) appliance.
6. Connect directly into a wall receptacle.
7. Be protected from exterior damage, i.e. environmental (weather) and physical (foot traffic).

Extension Cords Must Not:

1. Be longer than 100 feet.
2. Have more than one receptacle on each end.
3. Be frayed, deteriorated, spliced, or modified.
4. Pass through walls, doors, or windows.
5. Be stapled or attached to a floor, wall, or ceiling.
6. Be connected in series.
7. Create a tripping or other safety hazard.
8. Be unprotected where exposed to foot traffic, moving wheels, or falling debris to minimize tripping hazards and damage to the cords.

9. Be in a cable tray that is not intended for power cables.

## C. Multiplug Adapters

UC Davis Fire Prevention does not authorize the use of multi plug adaptors.

## D. Power Taps

A Relocatable Power Tap (RPT) or power strip is a variation of an extension cord, where the cord terminates in a row or grouping of receptacles. Power strips are commonly used in offices to provide multiple receptacles to office equipment. In general, the policies pertaining to extension cords also apply to power strips.

Power Taps Must:

1. Be of the polarized or grounded type, having over current protection.
2. Be UL 1363 listed.
3. Be connected directly to a permanently installed receptacle.
4. Be protected from exterior damage, i.e. environmental (weather) and physical (foot traffic).

Power Taps Must Not:

1. Be frayed, deteriorated, spliced, or modified.
2. Pass through walls, doors, or windows.
3. Be connected in series.

## E. Surge Suppressors and Protectors

Surge suppressors are commonly found in areas where the consistency of the electrical current is vital. The surge suppressor monitors electrical equipment, such as computers, and protects them from fluctuations in the electrical current supplied by campus. It is important to recognize that not all surge suppressors are power taps. The important distinction is the presence of over current protection in the form of a circuit breaker. If the surge suppressor also contains this over current protection feature, and the surge suppressor is UL listed for that feature, it may be used as a power tap. Be sure the total wattage of all connected devices does not exceed the total wattage rating on the surge suppressor.

Surge Suppressors/Protectors Must:

1. Be equipped with an automatic circuit breaker (outlet strips with fuses or without over current protection are not acceptable).
2. Have a cord no more than 15 feet long and must be directly plugged into a wall receptacle (any cord over 15 feet must be approved by the UC Davis Fire Department).
3. Be protected where exposed to foot or wheel traffic to minimize tripping hazards and damage to the cords.
4. Be UL 1449 listed "Transient Voltage Surge Suppressor".

Surge Suppressors/Protectors Must Not:

1. Have higher wattage appliances connected such as coffee pots, space heaters, microwave ovens, hot plates, refrigerators, or copy machines.
2. Be connected in series.

When choosing a surge protector, look for the following:

1. **The UL 1449 Suppressed Voltage rating:** This number reflects the amount of voltage the surge suppressor will let through to your connected equipment after "clamping".
2. **Stages of Protection/Surge Current Rating:** UL 1449 does not tell you how much surge current (in amps) can be handled or how quickly the suppressor will clamp. With multiple stages of protection, different components are used to suppress a surge. The more stages, the more surge current can be handled. The surge current rating in amps lets you know the maximum amount of surge current that can be safely handled by the suppressor. The higher the number, the better the rating.

1 stage - Good	2 stages - Better	3 stages - Best
----------------	-------------------	-----------------

3. **Clamping Response Time:** How quickly does the suppressor respond.

**Nanosecond** (billionths of a second) – Better

**Picosecond** (trillionths of a second) – Best

## SURGE PROTECTIVE DEVICES

MODEL: LTS-4G-W

VPR: 900V (L-N) TYPE 3 SPD

RATING: 15A 125VAC 60Hz 1875W

CONFORMS TO UL STD. 1363 and 1449

CERTIFIED TO CSA STD.C22.2 NO.308 & 8


FCC ID:2AMQ8-WIFI-003 Made In China

This device complies with part 15 of the  
FCC rules. Operation is subject to the  
following two conditions:

- (1) This device may not cause harmful interference, and
- (2) This device must accept any interference received, including interference that may cause undesired operation.



**Intertek**  
3165047



Updated March 2020

## Contact

### Fire Prevention Services

[fireprevention@ucdavis.edu](mailto:fireprevention@ucdavis.edu)

530-752-1493

For more information, please visit [safety-services.ucdavis.edu/safetynets](https://safety-services.ucdavis.edu/safetynets)